

MATS Strand Krokarehea Vannverk													
A	Måned	Fargetall	Lukt (TON)	Turbiditet	E.coli	Intestinale enterokokker	Totalt bakterietall (kimtall)	Koliforme bakterier	Surhetsgrad	Alkalitet	Jern	Kalsium	Total organisk karbon (TOC)
		mg Pt/l		FNU	MPN/100 ml	cfu/100 ml	cfu/ml	MPN/100 ml		mmol/L	µg/l	mg/l	mg/l
Prøvepunkt													
Renvann	01.01.23	2		0,05	0	0	0	0	8,4	0,68	49,5	18	
	01.02.23	1		0,05	0	0	0	0	8,5	0,68	22,0	18	
	01.03.23	1		0,05	0	0	0	0	8,4	0,74	15,0	19	
	01.04.23	1		0,05	0	0	0	0	8,4	0,74	8,7	19	
	01.05.23	1		0,05	0	0	0	0	8,3	0,75	14,0	18	
	01.06.23	1		0,05	0	0	0	0	8,3	0,75	9,1	19	
	01.07.23	1		0,05	0	0	0	0	8,3	0,76	7,8	19	
	01.08.23	1		0,05	0	0	0	0	8,4	0,76	6,8	19	
	01.09.23	1		0,05	0	0	0	0	8,3	0,76	7,9	19	
	01.10.23	1		0,05	0	0	0	0	8,2	0,77	7,2	19	
	01.11.23	1		0,05	0	0	0	0	8,4	0,73	5,8	19	
	01.12.23	1		0,05	0	0	0	0	8,3	0,74	20,0	19	
Leite Høydebasseng													
Nordmarka	01.01.23	1		0,05	0	0	1	0					
	01.02.23	1		0,05	0		2	0					
	01.03.23	1		0,05	0		0	0					
	01.04.23	1		0,05	0	0	1	0					
	01.05.23	1		0,05	0		1	0					
	01.06.23	1		0,05	0	0	0	0					
	01.07.23	1		0,05	0		0	0					
	01.08.23	1		0,05	0		0	0					
	01.09.23	1		0,05	0		0	0					
	01.10.23	1		0,05	0	0	0	0					
	01.11.23	1		0,05	0		0	0					
	01.12.23	1		0,05	0		0	0					
Fiskå nettvann	01.01.23				0		4	0					
	01.02.23				0		6	0					
	01.03.23				0		3	0					
	01.04.23				0		0	0					
	01.05.23				0		13	0					
	01.06.23				0		0	0					
	01.07.23				0		11	0					
	01.08.23				0		7	0					
	01.09.23				0		0	0					
	01.10.23				0		0	0					
	01.11.23				0		6	0					
	01.12.23				0		4	0					
Sum			0,00										0,00
Snitt		1		0,05	0	0	2	0	8,3	0,74	14,5	19	
Maks		2		0,05	0	0	13	0	8,5	0,77	49,5	19	
Min		1		0,05	0	0	0	0	8,2	0,68	5,8	18	
Antall		24	0	24	36	16	36	36	12	12	12	12	0
Median		1		0,05	0	0	0	0	8,3	0,75	8,9	19	